

宿迁宇新固体废物处置有限公司3月份信息公开内容

2025年3月危险废物经营情况汇总表

单位：吨

废物种类	进厂数量	处置量	1号炉	2号炉	利用量	移出数量	产品数量	上月库存	本月库存
HW02	697.953	629.0355	372.0464	256.9891				265.767	334.6845
HW04	803.586	717.8131	333.4993	384.3138				420.5701	506.343
HW06	392.5057	426.0993	187.1628	238.9365				189.8716	156.278
HW08	193.1092	24.7659	15.3718	9.3941				2.2958	170.6391
HW09	-	50.346	12.327	38.019				79.45	29.104
HW11	366.0815	369.7835	164.8466	204.9369				630.828	627.126
HW12	112.0716	69.4536	17.4626	51.991				48.0545	90.6725
HW13	28.0862	42.1915	28.1031	14.0884				31.7915	17.6862
HW16	0.8	0.55	0.3667	0.1833				-	0.25
HW17	13.8806	13.544	2.0625	11.4815				10.244	10.5806
HW34	66.741	40.017	12.5993	27.4177				174.593	201.317
HW35	3.83	2.78	1.668	1.112				-	1.05
HW39	-	0.064	0.064	-				0.064	-
HW45	69.6715	161.0845	65.1816	95.9029				121.338	29.925
HW49	1012.6786	763.0351	335.1187	427.9164				950.53033	1200.17383
HW50	0.433	16.437	3.3096	13.1274				16.437	0.433
月度合计	3761.4279	3327	1551.19	1775.81				2941.83483	3376.26273

202503新生废物月表

查询时间：2025-03-01 -- 2025-03-31

导出时间：2025-04-01

序号	废物名称	废物代码	单位	产生量	处置量				期初库存量	期末库存量
					焚烧	填埋	利用	其他		
	合计			978.872	0.04	967.56	29		227.905	210.177
1	废铁皮	772-003-18	吨	11.273		-	29		27.457	9.73
2	飞灰	772-003-18	吨	436.747		400.545			44.495	80.697
3	炉渣	772-003-18	吨	458.898		475.6			116.83	100.128
4	急冷塔灰	772-003-18	吨	71.914		91.415			39.063	19.562
5	废包装桶	900-041-49	只	2280只			2412只		524只	392只
6	废滤袋	900-041-49	吨	0.02	0.02				0	0
7	实验室废液	900-047-49	吨	0.02	0.02				0.06	0.06

3月份监测报告

一、有组织废气

采样日期	检测点位	检测项目	样品描述	检测结果				排气筒高度(m)
				频次	标干流量(m³/h)	排放浓度(mg/m³)	排放速率(kg/h)	
2025.01.14	DA001料坑及暂存库废气排放口①	氨	吸收液	第一次	78394	0.44	3.45×10 ⁻²	20
				第二次	75733	0.51	3.86×10 ⁻²	
				第三次	79462	0.59	4.69×10 ⁻²	
				第四次	77877	0.66	5.14×10 ⁻²	
				最大值	/	/	5.14×10 ⁻²	
				标准限值	/	/	≤8.7	
		硫化氢	吸收液	第一次	78394	0.01	7.84×10 ⁻⁴	
				第二次	75733	ND	/	
				第三次	79462	0.01	7.95×10 ⁻⁴	
				第四次	77877	0.01	7.79×10 ⁻⁴	
				最大值	/	/	7.95×10 ⁻⁴	
				标准限值	/	/	≤0.58	

采样日期	检测点位	检测项目	样品描述	检测结果				排气筒高度(m)
				频次	标干流量(m³/h)	排放浓度(mg/m³)	排放速率(kg/h)	
2025.01.14	DA001料坑及暂存库废气排放口①	氟化物	滤筒+吸收液	第一次	76744	0.11	8.44×10 ⁻³	20
				第二次	74756	0.13	9.72×10 ⁻³	
				第三次	75887	0.12	9.11×10 ⁻³	
				均值	75796	0.12	9.10×10 ⁻³	
				标准限值	/	≤3	≤0.072	
				第一次	76744	ND	/	
		氯化氢	吸收液	第二次	74756	ND	/	
				第三次	75887	ND	/	
				均值	75796	ND	/	
				标准限值	/	≤10	≤0.18	
		挥发性有机物	吸附管	第一次	76340	1.61	0.123	
				第二次	80242	1.27	0.102	
				第三次	79462	1.28	0.102	
				均值	78681	1.39	0.109	
				标准限值	/	≤60	≤3	
		非甲烷总烃	气袋	第一次	76340	4.64	0.354	
				第二次	80242	6.33	0.508	
				第三次	79462	3.86	0.307	
				均值	78681	4.94	0.389	
				标准限值	/	97	/	
		臭气浓度(无量纲)	气袋	第二次	/	72	/	
				第三次	/	85	/	
				第四次	/	63	/	
				最大值	/	97	/	
				标准限值	/	≤4000	/	
				第一次	78394	1.2	9.41×10 ⁻²	
				第二次	75733	1.1	8.51×10 ⁻²	
				第三次	79462	1.3	9.72×10 ⁻²	
				均值	77877	1.2	9.05×10 ⁻²	
				标准限值	/	≤1	≤0.1	
				第一次	78394	1.2	9.41×10 ⁻²	

检测日期	检测点位	检测项目	样品描述	检测结果				排气筒高度(m)
				频次	标干流量(m³/h)	排放浓度(mg/m³)	排放速率(kg/h)	
2025.01.14	DA002渣库废气排口②	非甲烷总烃	气袋	第一次	31913	1.84	5.87×10 ⁻²	15
				第二次	32527	1.54	5.01×10 ⁻²	
				第三次	32606	1.67	5.45×10 ⁻²	
				均值	32349	1.68	5.43×10 ⁻²	
		氨	吸收液	第一次	32925	0.29	9.55×10 ⁻³	
				第二次	31999	ND	/	
				第三次	33237	0.37	1.23×10 ⁻²	
				第四次	34702	0.40	1.39×10 ⁻²	
				最大值	/	/	1.39×10 ⁻²	
				标准限值	/	/	≤4.9	
		硫化氢	吸收液	第一次	32925	ND	/	
				第二次	31999	ND	/	
				第三次	33237	0.01	3.32×10 ⁻⁴	
				第四次	34702	0.01	3.47×10 ⁻⁴	
				最大值	/	/	3.47×10 ⁻⁴	
				标准限值	/	/	≤0.33	
		氟化物	滤筒+吸收液	第一次	33237	0.21	6.98×10 ⁻³	
				第二次	32399	0.19	6.33×10 ⁻³	
				第三次	33360	0.21	7.01×10 ⁻³	
				均值	33299	0.20	6.66×10 ⁻³	
				标准限值	/	≤3	≤0.072	
		氯化氢	吸收液	第一次	31913	ND	/	
				第二次	32527	ND	/	
				第三次	32606	ND	/	
				均值	32349	ND	/	
				标准限值	/	≤10	≤0.18	
		低浓度颗粒物	低浓度采样头	第一次	32925	2.0	6.58×10 ⁻²	
				第二次	32143	1.4	4.50×10 ⁻²	
				第三次	31999	1.2	3.84×10 ⁻²	
				均值	32356	1.5	4.85×10 ⁻²	
				标准限值	/	≤20	≤1	
	DA002渣库废气排口②	挥发性有机物	吸附管	第一次	31913	0.08	2.55×10 ⁻³	15
				第二次	32527	0.11	3.58×10 ⁻³	
				第三次	32606	0.07	2.28×10 ⁻³	
				均值	32349	0.09	2.91×10 ⁻³	
				标准限值	/	≤60	≤3	
		臭气浓度(无量纲)	臭气袋	第一次	/	72	/	
				第二次	/	97	/	
				第三次	/	63	/	
				第四次	/	72	/	
				最大值	/	97	/	
				标准限值	/	≤2000	/	

检测日期	检测点位	检测项目	样品描述	检测结果				排气筒高度 (m)
				频次	标干流量 (m³/h)	排放浓度 (mg/m³)	排放速率 (kg/h)	
2025.01.14	DA005 废气出口口3	甲烷	气袋	第一次	17456	1.48	2.58×10 ⁻²	15
				第二次	17584	1.43	2.51×10 ⁻²	
				第三次	17536	1.41	2.47×10 ⁻²	
				均值	17525	1.44	2.52×10 ⁻²	
		氯化氢	吸收液	第一次	15800	ND	/	
				第二次	17526	ND	/	
				第三次	16949	ND	/	
				均值	16758	ND	/	
		挥发性有机物	吸附管	标准限值	/	≤10	≤0.18	
				第一次	17456	ND	/	
				第二次	17584	ND	/	
				第三次	17536	ND	/	
				均值	17525	ND	/	
		氯气	吸收液	标准限值	/	≤60	≤3	
				第一次	15800	0.5	7.90×10 ⁻³	
				第二次	17526	0.6	1.05×10 ⁻²	
				第三次	16949	0.6	1.02×10 ⁻²	
		氨	吸收液	均值	16758	0.6	1.01×10 ⁻²	
				第一次	15792	0.51	8.05×10 ⁻³	
				第二次	16716	0.57	6.18×10 ⁻³	
				第三次	17607	0.58	1.02×10 ⁻²	
		硫化氢	吸收液	第四次	17020	0.44	7.49×10 ⁻³	
				最大值	/	/	1.02×10 ⁻²	
				标准限值	/	/	≤4.9	
				第一次	15792	ND	/	
				第二次	16716	ND	/	
				第三次	17607	ND	/	
				第四次	17020	ND	/	
				最大值	/	/	/	
				标准限值	/	/	≤0.58	

目标物	检测结果 (mg/m³)			检出限 (mg/m³)
	DA001 料坑及暂存库废气排口 ①			
	第一次	第二次	第三次	
丙酮	0.55	0.38	0.35	0.01
异丙醇	ND	ND	ND	0.002
正己烷	0.170	0.143	0.144	0.004
乙酸乙酯	ND	0.015	0.033	0.006
苯	ND	ND	ND	0.004
六甲基二硅氧烷	ND	ND	ND	0.001
3-戊酮	ND	ND	ND	0.002
正庚烷	0.323	0.273	0.261	0.004
甲苯	0.555	0.456	0.462	0.004
环戊酮	ND	ND	ND	0.004
乳酸乙酯	ND	ND	ND	0.007
乙酸丁酯	ND	ND	ND	0.005
丙二醇单甲醚乙酸酯	ND	ND	ND	0.005
乙苯	0.011	0.008	0.021	0.006
对/间二甲苯	ND	ND	ND	0.009
2-庚酮	ND	ND	ND	0.001
苯乙烯	ND	ND	0.007	0.004
邻二甲苯	ND	ND	ND	0.004
苯甲醛	ND	ND	ND	0.003
苯甲醚	ND	ND	ND	0.007
1-癸烯	ND	ND	ND	0.003
2-壬酮	ND	ND	ND	0.003
1-十二烯	ND	ND	ND	0.008

注：ND 表示未检出。

采样日期	检测点位	检测项目	样品描述	检测结果				排气筒高度(m)
				频次	标干流量(m³/h)	排放浓度(mg/m³)	排放速率(kg/h)	
2025.03.03	DA003 排口②1	低浓度颗粒物	低浓度采样头	第一次	22407	1.3	2.69×10 ⁻²	50
				第二次	22557	3.6	4.06×10 ⁻²	
				第三次	22147	4.1	6.42×10 ⁻²	
				均值	22370	3.0	4.39×10 ⁻²	
				标准限值		/	≤15	
		二氧化硫	/	第一次	22407	ND	/	
				第二次	22557	ND	/	
				第三次	22147	ND	/	
				均值	22370	ND	/	
				标准限值		/	≤50	
		氮氧化物	/	第一次	22407	43	0.896	
				第二次	22557	68	0.767	
				第三次	22147	49	0.775	
				均值	22370	53	0.813	
				标准限值		/	≤200	
		一氧化碳	/	第一次	22407	15	0.314	
				第二次	22557	20	0.226	
				第三次	22147	10	0.155	
				均值	22370	15	0.231	
				标准限值		/	≤100	
		烟气黑度		≤1				
		标准限值		≤1				

采样日期	检测点位	检测项目	样品描述	检测结果				排气筒高度 (m)
				频次	标干流量 (m³/h)	排放浓度 (mg/m³)	排放速率 (kg/h)	
2025.03.03	DA003 排口口1	颗粒物中铅	滤筒	第一次	20893	1.26×10 ⁻²	1.58×10 ⁻⁴	50
				第二次	21248	1.36×10 ⁻²	1.97×10 ⁻⁴	
				第三次	20440	1.06×10 ⁻²	1.58×10 ⁻⁴	
				均值	20860	1.23×10 ⁻²	1.71×10 ⁻⁴	
		颗粒物中砷	滤筒	标准限值	/	≤0.5	/	
				第一次	20893	0.100	1.26×10 ⁻³	
				第二次	21248	0.104	1.50×10 ⁻³	
				第三次	20440	0.130	1.94×10 ⁻³	
				均值	20860	0.111	1.57×10 ⁻³	
		颗粒物中铬	滤筒	标准限值	/	≤0.5	/	
				第一次	20893	0.197	2.47×10 ⁻³	
				第二次	21248	0.150	2.17×10 ⁻³	
				第三次	20440	0.260	3.88×10 ⁻³	
				均值	20860	0.202	2.84×10 ⁻³	
		颗粒物中镍	滤筒	标准限值	/	≤0.5	/	
				第一次	20893	9.35×10 ⁻²	1.17×10 ⁻³	
				第二次	21248	5.51×10 ⁻²	7.97×10 ⁻⁴	
				第三次	20440	0.127	1.89×10 ⁻³	
				均值	20860	9.19×10 ⁻³	1.29×10 ⁻³	
		颗粒物中铜	滤筒	第一次	20893	5.33×10 ⁻³	6.69×10 ⁻⁵	
				第二次	21248	4.91×10 ⁻³	7.10×10 ⁻⁵	
				第三次	20440	7.14×10 ⁻³	1.06×10 ⁻⁴	
				均值	20860	5.79×10 ⁻³	8.14×10 ⁻⁵	
		颗粒物中锰	滤筒	第一次	20893	4.18×10 ⁻²	5.24×10 ⁻⁴	
				第二次	21248	4.01×10 ⁻²	5.80×10 ⁻⁴	
				第三次	20440	4.89×10 ⁻²	7.30×10 ⁻⁴	
				均值	20860	4.36×10 ⁻²	6.11×10 ⁻⁴	

检测日期	检测点位	检测项目	样品描述	检测结果				排气筒高度 (m)
				频次	标干流量 (m³/h)	排放浓度 (mg/m³)	排放速率 (kg/h)	
2025.01.14	DA005 废气出口口3	非甲烷总烃	气袋	标准限值	/	≤2000	/	15
				第一次	17456	1.57	2.74×10 ⁻²	
				第二次	17584	1.50	2.64×10 ⁻²	
				第三次	17536	1.52	2.67×10 ⁻²	
				均值	17525	1.53	2.68×10 ⁻²	
		臭气浓度 (无量纲)	气袋	标准限值	/	≤60	≤3	
				第一次	/	63	/	
				第二次	/	72	/	
				第三次	/	63	/	
				第四次	/	85	/	
				最大值	/	85	/	
		氯化物	滤筒+吸收液	标准限值	/	≤2000	/	
				第一次	15800	0.21	3.32×10 ⁻³	
				第二次	17526	0.18	3.15×10 ⁻³	
				第三次	16949	0.20	3.39×10 ⁻³	
				均值	16758	0.20	3.35×10 ⁻³	
				标准限值	/	≤3	≤0.072	

检测日期	检测点位	检测项目	样品描述	检测结果				排气筒高度 (m)
				频次	标干流量 (m³/h)	排放浓度 (mg/m³)	排放速率 (kg/h)	
2025.01.14	DA005 医疗废气排口口3	硫酸雾	滤筒+吸收液	第一次	17456	0.71	1.24×10 ⁻²	15
				第二次	17584	0.73	1.28×10 ⁻²	
				第三次	17536	0.74	1.30×10 ⁻²	
				均值	17525	0.73	1.28×10 ⁻²	
		低浓度颗粒物	低浓度采样头	第一次	16716	1.4	2.34×10 ⁻²	
				第二次	17064	1.3	2.22×10 ⁻²	
				第三次	18058	1.3	2.35×10 ⁻²	
				均值	17279	1.3	2.25×10 ⁻²	
				标准限值	/	≤20	≤1	
				第一次	17456	0.71	1.24×10 ⁻²	
				第二次	17584	0.73	1.28×10 ⁻²	
				第三次	17536	0.74	1.30×10 ⁻²	
				均值	17525	0.73	1.28×10 ⁻²	

目标物	检测结果 (mg/m³)							检出限 (mg/m³)
	DA002 渣库废气排口②			DA005 废气排口③				
	第一次	第二次	第三次	第一次	第二次	第三次		
丙酮	0.08	0.11	0.07	ND	ND	ND	0.01	
异丙醇	ND	ND	ND	ND	ND	ND	0.002	
正己烷	ND	ND	ND	ND	ND	ND	0.004	
乙酸乙酯	ND	ND	ND	ND	ND	ND	0.006	
苯	ND	ND	ND	ND	ND	ND	0.004	
六甲基二硅氧烷	ND	ND	ND	ND	ND	ND	0.001	
3-戊酮	ND	ND	ND	ND	ND	ND	0.002	
正庚烷	ND	ND	ND	ND	ND	ND	0.004	
甲苯	ND	ND	ND	ND	ND	ND	0.004	
环戊酮	ND	ND	ND	ND	ND	ND	0.004	
乳酸乙酯	ND	ND	ND	ND	ND	ND	0.007	
乙酸丁酯	ND	ND	ND	ND	ND	ND	0.005	
丙二醇单甲醚乙酸酯	ND	ND	ND	ND	ND	ND	0.005	
乙苯	ND	ND	ND	ND	ND	ND	0.006	
对/间二甲苯	ND	ND	ND	ND	ND	ND	0.009	
2-庚酮	ND	ND	ND	ND	ND	ND	0.001	
苯乙烯	ND	ND	ND	ND	ND	ND	0.004	
邻二甲苯	ND	ND	ND	ND	ND	ND	0.004	
苯甲醚	ND	ND	ND	ND	ND	ND	0.003	
苯甲醛	ND	ND	ND	ND	ND	ND	0.007	
1-癸烯	ND	ND	ND	ND	ND	ND	0.003	
2-壬酮	ND	ND	ND	ND	ND	ND	0.003	
1-十二烯	ND	ND	ND	ND	ND	ND	0.008	

注：ND 表示未检出。

					第一次	21764	1.40×10^{-2}	1.95×10^{-4}		
					第二次	21588	1.10×10^{-2}	1.96×10^{-4}		
					第三次	22000	7.20×10^{-3}	1.27×10^{-4}		
					均值	21784	1.07×10^{-2}	1.27×10^{-4}		
2025.03.03	DA004 出口②2	颗粒物 中钴	滤筒	频次	标干流量 (m³/h)	排放浓度 (mg/m³)	排放速率 (kg/h)	50		
				第一次	21764	ND	/			
				第二次	21588	ND	/			
				第三次	22000	ND	/			
				均值	21784	ND	/			
		Co+Sn+Sb+Cu+Mn+Ni 总计				/	7.19×10^{-2}	/		
		Co+Sn+Sb+Cu+Mn+Ni 标准限值				/	≤2.0	/		
		汞及其 化合物	滤筒	第一次	21063	1.51×10^{-3}	2.61×10^{-5}			
				第二次	22497	3.62×10^{-3}	5.94×10^{-5}			
				第三次	20828	2.92×10^{-3}	4.75×10^{-5}			
				均值	21463	2.68×10^{-3}	4.43×10^{-5}			
				标准限值				/	≤0.05	/
		颗粒物 中镉	滤筒	第一次	21764	ND	/			
				第二次	21588	ND	/			
				第三次	22000	ND	/			
				均值	21784	ND	/			
				标准限值				/	≤0.05	/
		烟气黑度（级）				≤1				
		标准限值（级）				≤1				
		氯化氢	吸收液	第一次	21063	ND	/			
				第二次	22497	ND	/			
				第三次	20828	ND	/			
				均值	21463	ND	/			
				标准限值				/	≤60	/

采样日期	检测点位	检测项目	样品描述	检测结果				排气筒高度(m)
				频次	标干流量(m³/h)	排放浓度(mg/m³)	排放速率(kg/h)	
2025.03.03	DA004出口②	氨化氢	吸收液	第一次	21063	1.24	2.15×10 ⁻²	50
				第二次	22497	1.32	2.16×10 ⁻²	
				第三次	20828	0.96	1.56×10 ⁻²	
				均值	21463	1.17	1.96×10 ⁻²	
		标准限值			/	≤4.0	/	

二、无组织废气

采样日期	检测项目	样品描述	检测点位	检测结果			
2025.01.14	氨 (mg/m ³)	吸收液	上风向○1	0.04	0.04	0.03	0.01
			下风向○2	0.04	0.02	0.02	0.03
			下风向○3	0.02	0.02	0.03	0.02
			下风向○4	0.01	0.02	0.01	0.02
			下风向浓度最大值	0.04			
		标准限值	≤1.5				
	硫化氢 (mg/m ³)	吸收液	上风向○1	ND	0.003	0.003	0.004
			下风向○2	0.005	0.001	0.002	0.002
			下风向○3	0.003	0.002	ND	0.002
			下风向○4	0.003	0.002	0.001	0.001
			下风向浓度最大值	0.005			
		标准限值	≤0.06				
	臭气浓度 (无量纲)	真空瓶	上风向○1	<10	<10	<10	<10
			下风向○2	<10	<10	<10	<10
			下风向○3	<10	<10	<10	<10
			下风向○4	<10	<10	<10	<10
			下风向浓度最大值	<10			
		标准限值	≤20				

三：噪声

检测日期	检测点位	检测结果 dB(A)
		夜间
2025.02.16	▲1	50.3
	▲2	50.0
	▲3	50.2
	▲4	47.7
	标准限值	≤55

采样日期	检测点位	样品描述	检测项目	检测结果	标准限值	计量单位		
2025.01.14	废水总排口★1	无色、无味、液态	pH 值	7.1 (9.7℃)	6-9	无量纲		
			悬浮物	9	≤200	mg/L		
			化学需氧量	14	≤500	mg/L		
			氨氮	0.114	≤45	mg/L		
			总磷	0.02	≤3	mg/L		
			总氮	1.34	≤70	mg/L		
			五日生化需氧量	2.8	≤300	mg/L		
			氟化物(氟离子)	3.11	≤20	mg/L		
			铬	0.03L	≤1.5	mg/L		
			铅	0.07L	≤1.0	mg/L		
			镉	0.007L	≤1.0	mg/L		
			总氯	0.08	≤85	mg/L		
			全盐量	382	≤8000	mg/L		
			阴离子表面活性剂	0.05L	≤20	mg/L		
			总氰化物	0.004L	≤0.5	mg/L		
			挥发酚	0.01L	≤2.0	mg/L		
			动植物油类	0.06L	/	mg/L		
			石油类	0.06L	/	mg/L		
			色度	3 (pH=7.4, 无色, 透明)	≤64	倍		
			污水处理进口★2	微灰、无味、液态	pH 值	7.2 (10.1℃)	/	无量纲
					化学需氧量	196	/	mg/L
					氨氮	27.6	/	mg/L
					总磷	2.32	/	mg/L
铅	0.07L	/			mg/L			
铬	0.03L	/			mg/L			
镍	0.007L	/			mg/L			
石油类	0.33	/			mg/L			
悬浮物	15	/			mg/L			
废水焚烧车间出口★3	黑色、无味、有油膜	pH 值			8.0 (11.3℃)	/	无量纲	
		化学需氧量	3.09×10 ⁴	/	mg/L			
		氨氮	660	/	mg/L			

采样日期	检测点位	样品描述	检测项目	检测结果	标准限值	计量单位
2025.01.14	废水焚烧车间出口★3	黑色、无味、有油膜	总磷	180	/	mg/L
			铬	0.09	/	mg/L
			铅	0.43	/	mg/L
			镍	1.55	/	mg/L
			钒	0.02L	/	mg/L
			锡	0.005L	/	mg/L
			总汞	4×10 ⁻⁶ L	/	mg/L
			砷	0.214	/	mg/L
			六价铬	0.004L	/	mg/L
			石油类	7.45	/	mg/L
悬浮物	4.62×10 ³	/	mg/L			

注：1.标准依据企业排污许可证，证书编号：9132130033637687X1002V。
2.未检出以“方法检出限”+“L”表示。

表 2 雨水检测结果						
采样日期	检测点位	样品描述	检测项目	检测结果	标准限值	计量单位
2025.01.14	DW002 雨水排口★4	微黄、无味、液态	氨氮	0.303		mg/L

采样日期	检测点位	样品描述	检测项目	检测结果	计量单位
2025.03.02	雨水排口 DW002★1	无色、无味、液态	化学需氧量	18	mg/L
			悬浮物	8	mg/L

表 1 废水检测结果						
采样日期	检测点位	样品描述	检测项目	检测结果	标准限值	计量单位
2025.03.03	废水排口★1	无色、无味、液态	粪大肠菌群	1.3×10 ³	≤1000	MPN/L

注：标准依据企业排污许可证，证书编号：9132130033637687X1002V。

四、固废

采样日期	采样点位	检测项目	样品描述	检测结果(%)
2025.01.14	■11号炉	热灼减率	黑色、刺激性气味、固体	1.59
	■22号炉	热灼减率	黑色、刺激性气味、固体	3.13
	标准限值			<5
注：标准限值由企业提供。				